NATA
WORLD RECOGNISED ACCREDITATION

Corporate Accreditation No 63

Accredited for compliance with ISO/IEC 17025 - Testing

Sydney WATER
Laboratory Services

Delivery Address: Sydney Water Corporation
51 Hermitage Rd
West Ryde NSW 2114

Telephone: [redacted]
Email: [redacted]

Analytical Report 290842

Issue Date: 09/09/2023
Issued By : Sydney Water Laboratory Services

Attention: [redacted]
Customer: Department of Planning and Environment
Customer ID: [redacted]

Address: [redacted]
Telephone: [redacted]
Email: [redacted]

CONTENTS

1. Sydney Water Approved Signatory
2. Sample Summary
3. Analytical results
4. Comments
5. Laboratory QC results

Sydney Water Approved Signatory

[redacted] Phycology Analyst
[redacted] Phycology Analyst
[redacted] Organics Analyst
[redacted] Organics Analyst

Where a result is required to meet a compliance limit or specification the associated uncertainty must be considered. Uncertainty estimates are available for all accredited test results.

Sydney WATER Laboratory Services

SAMPLE SUMMARY

Client Sample ID	Sample Number	Sampling Procedure	Date Sampled	Date Received	Date Authorised	Description
237925	L23069722	1	24/08/2023	28/08/2023	06/09/2023	E11 (WATER SAMPLE)
237926	L23069723	1	24/08/2023	28/08/2023	06/09/2023	E12 (WATER SAMPLE)
237927	L23069724	1	24/08/2023	28/08/2023	06/09/2023	E13 (WATER SAMPLE)
237928	L23069725	1	24/08/2023	28/08/2023	06/09/2023	E14 (WATER SAMPLE)
237929	L23069726	1	24/08/2023	28/08/2023	06/09/2023	E15 (WATER SAMPLE)
237930	L23069727	1	24/08/2023	28/08/2023	08/09/2023	E11 (WATER SAMPLE)
237931	L23069728	1	24/08/2023	28/08/2023	07/09/2023	E12 (WATER SAMPLE)
237932	L23069729	1	24/08/2023	28/08/2023	07/09/2023	E13 (WATER SAMPLE)
237933	L23069730	1	24/08/2023	28/08/2023	07/09/2023	E14 (WATER SAMPLE)
237934	L23069731	1	24/08/2023	28/08/2023	07/09/2023	E15 (WATER SAMPLE)

Sampling procedures

1 Samples analysed as received.
2 Samples collected as per FS procedures SAWI 070, Excluding Oil & Grease which is collected as per clients instructions.
3 Samples collected as per FS procedures SAWI 070.
4 Results reported as received from WNSW.

Sydney WATER Laboratory Services

ANALYTICAL RESULTS

Client Sample ID		237925	237926	237927	237928	237929	237930	237931	237932
Sampled Date		24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM
Sample Number		L23069722	L23069723	L23069724	L23069725	L23069726	L23069727	L23069728	L23069729
ALGAL									
MA71CENT : Blue-Green ID & Enumeration, Including ASU & Biovolumes									
Blue Green ASU	ASU/mL	-	-	-	-	-	2663	18670	14860
Blue Green Biovol	mm3/L	-	-	-	-	-	1.87	22.47	18.12
Potentially Toxic Blue Green	cells/mL	-	-	-	-	-	69860	928500	834500
Potentially Toxic Blue Green ASU	ASU/mL	-	-	-	-	-	1174	15600	14020
Potentially Toxic Blue Green Biovol	mm3/L	-	-	-	-	-	1.42	18.92	17.01
Total Blue Green	cells/mL	-	-	-	-	-	842700	1837000	1011000
MA91 : Individual Species Total Count, Total BioVol, Total ASU									
Algae Source*	N/A	-	-	-	-	-	EXTERNAL	EXTERNAL	EXTERNAL
Date of Performance	DD/MM/YY						07/09/23 00:00	07/09/23 00:00	07/09/23 00:00
ORGANICS									
TC0049DW : Algal Toxins									

* Indicates NATA accreditation does not cover the performance of this service

"-" = Not required or refer to Laboratory comment

Sydney WATER Laboratory Services

Client Sample ID		237925	237926	237927	237928	237929	237930	237931	237932
Sampled Date		24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM
Sample Number		L23069722	L23069723	L23069724	L23069725	L23069726	L23069727	L23069728	L23069729
ORGANICS									
TC0049DW : Algal Toxins(Continued)									
Cylindrospermopsin (extra cellular)	ug/L	<0.05	<0.05	<0.05	0.11	0.13	-	-	-
Cylindrospermopsin (intra cellular)	ug/L	<0.05	<0.05	0.06	<0.05	<0.05	-	-	-
Anatoxin-a(extracellular)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	-	-	-
Anatoxin-a(intracellular)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	-	-	-
Nodularin (extracellular)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	-	-	-
Nodularin (intracellular)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	-	-	-
Microcystin RR(extracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-
Microcystin YR(extracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-
Microcystin LR(extracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-
Microcystin LR(intracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-

* Indicates NATA accreditation does not cover the performance of this service

"-" = Not required or refer to Laboratory comment

Sydney WATER Laboratory Services

Client Sample ID		237925	237926	237927	237928	237929	237930	237931	237932
Sampled Date		24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM
Sample Number		L23069722	L23069723	L23069724	L23069725	L23069726	L23069727	L23069728	L23069729
ORGANICS									
TC0049DW : Algal Toxins(Continued)									
Microcystin YR(intracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-
Microcystin RR(intracellular)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-
Anatoxin-a(total)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	-	-	-
Cylindrospermopsin(total)	ug/L	<0.05	<0.05	0.06	0.12	0.13	-	-	-
Microcystin LR(total)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-
Microcystin RR(total)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-
Microcystin YR(total)	ug/L	<0.05	<0.05	<0.05	<0.05	<0.05	-	-	-
Nodularin (total)	ug/L	<0.1	<0.1	<0.1	<0.1	<0.1	-	-	-
Date of Performance	DD/MM/YY	28/08/23	28/08/23	28/08/23	28/08/23	28/08/23			
TC0061DW : Paralytic Shellfish Toxins (PST) Analysis by UPLCMSMS									
Saxitoxin	ug/L	<0.4	<0.4	<0.4	<0.4	<0.4	-	-	-
Neosaxitoxin	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	-	-	-

* Indicates NATA accreditation does not cover the performance of this service

"-" = Not required or refer to Laboratory comment

Sydney WATER Laboratory Services

Client Sample ID		237925	237926	237927	237928	237929	237930	237931	237932
Sampled Date		24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM
Sample Number		L23069722	L23069723	L23069724	L23069725	L23069726	L23069727	L23069728	L23069729
ORGANICS									
TC0061DW : Paralytic Shellfish Toxins (PST) Analysis by UPLCMSMS(Continued)									
dcSTX	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	-	-	-
C2	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	-	-	-
GTX4	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	-	-	-
GTX3	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	-	-	-
GTX5	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	-	-	-
dcNeo	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	-	-	-
dcGTX3	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	-	-	-
GTX6	ug/L	<0.3	<0.3	<0.3	<0.3	<0.3	-	-	-
GTX2	ug/L	<1	<1	<1	<1	<1	-	-	-
GTX1	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	-	-	-
C1	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	-	-	-
dcGTX2	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	-	-	-

* Indicates NATA accreditation does not cover the performance of this service

"-" = Not required or refer to Laboratory comment

Sydney WATER Laboratory Services

Client Sample ID		237925	237926	237927	237928	237929	237930	237931	237932
Sampled Date		24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM
Sample Number		L23069722	L23069723	L23069724	L23069725	L23069726	L23069727	L23069728	L23069729
ORGANICS									
Date of Performance	DD/MM/YY	04/09/23	04/09/23	04/09/23	04/09/23	04/09/23			

Client Sample ID		237933	237934						
Sampled Date		24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM						
Sample Number		L23069730	L23069731						
ALGAL									
MA71CENT : Blue-Green ID & Enumeration, Including ASU & Biovolumes									
Blue Green ASU	ASU/mL	24330	28260						
Blue Green Biovol	mm3/L	29.45	34.19						
Potentially Toxic Blue Green	cells/mL	1423000	1666000						
Potentially Toxic Blue Green ASU	ASU/mL	23970	28030						
Potentially Toxic Blue Green Biovol	mm3/L	29.13	34.02						
Total Blue Green	cells/mL	1473000	1722000						

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

Client Sample ID		237933	237934						
Sampled Date		24/08/2023 12:00:00 AM	24/08/2023 12:00:00 AM						
Sample Number		L23069730	L23069731						
ALGAL									
MA91 : Individual Species Total Count, Total BioVol, Total ASU									
Algae Source*	N/A	EXTERNAL	EXTERNAL						
Date of Performance	DD/MM/YY	07/09/23 00:00	07/09/23 00:00						

COMMENTS

Sample ID	Comment Level	Method	Test	Comment
L23069727	Method	MA91	-	Debris present in the sample.
L23069728	Method	MA91	-	Debris present in the sample.
L23069729	Method	MA91	-	Debris present in the sample.
L23069730	Method	MA91	-	Debris present in the sample.
L23069731	Method	MA91	-	Debris present in the sample.

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

LABORATORY QC RESULTS

N/A - Not Applicable
PQL - Practical Quantitation Limit
LOQ - Limit of Quantification
RPD - Relative Percent Difference
SPIKE/Positive Control - Addition of a known amount and concentration
Duplicate Precision = Accepted - Result 2 within 95% confidence limits of result 1
Duplicate Precision = Outlier - Result 2 outside 95% confidence limits of result 1
Duplicate Precision = Not calculated - Result is outside test range

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

LOQ	Blank	Control *Acceptance Criteria*	Spike *Acceptance Criteria*	Duplicate1	Duplicate2	RPD *Acceptance Criteria*
TC0049DW Anatoxin-a(extracellular)						
<0.1 ug/L	**<0.1**	**82** *50.0 - 120.0 ug/L*	**58 % Recovery** *50.0 - 130.0 % Recovery*	**<0.1**	**<0.1**	**B** *0.0 - 0.0 %*
TC0049DW Anatoxin-a(intracellular)						
<0.1 ug/L	**F**		**E**	**<0.1**	**<0.1**	**B** *0.0 - 0.0 %*
TC0049DW Anatoxin-a(total)						
<0.1 ug/L	**F**		**E**	**<0.1**	**<0.1**	**B** *0.0 - 0.0 %*
TC0049DW Cylindrospermopsin (extracellular)						
<0.05 ug/L	**<0.05**	**85** *50.0 - 120.0 ug/L*	**74 % Recovery** *50.0 - 130.0 % Recovery*	**0.13**	**0.13**	**B** *0.0 - 0.0 %*
TC0049DW Cylindrospermopsin (intracellular)						
<0.05 ug/L	**F**		**E**	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Cylindrospermopsin(total)						
<0.05 ug/L	**F**		**E**	**0.13**	**0.13**	**B** *0.0 - 0.0 %*

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

LOQ	Blank	Control *Acceptance Criteria*	Spike *Acceptance Criteria*	Duplicate1	Duplicate2	RPD *Acceptance Criteria*
TC0049DW Microcystin LR(extracellular)						
<0.05 ug/L	**<0.05**	**72** *50.0 - 120.0 ug/L*	**51 % Recovery** *50.0 - 130.0 % Recovery*	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Microcystin LR(intracellular)						
<0.05 ug/L	**F**		**E**	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Microcystin LR(total)						
<0.05 ug/L	**F**		**E**	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Microcystin RR(extracellular)						
<0.05 ug/L	**<0.05**	**85** *50.0 - 120.0 ug/L*	**46 % Recovery** *50.0 - 130.0 % Recovery*	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Microcystin RR(intracellular)						
<0.05 ug/L	**F**		**E**	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Microcystin RR(total)						
<0.05 ug/L	**F**		**E**	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Microcystin YR(extracellular)						
<0.05 ug/L	**<0.05**	**85** *50.0 - 120.0 ug/L*	**55 % Recovery** *50.0 - 130.0 % Recovery*	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

LOQ	Blank	Control *Acceptance Criteria*	Spike *Acceptance Criteria*	Duplicate1	Duplicate2	RPD *Acceptance Criteria*
TC0049DW Microcystin YR(intracellular)						
<0.05 ug/L	**F**		**E**	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Microcystin YR(total)						
<0.05 ug/L	**F**		**E**	**<0.05**	**<0.05**	**B** *0.0 - 0.0 %*
TC0049DW Nodularin (extracellular)						
<0.1 ug/L	**<0.1**	**81** *50.0 - 120.0 ug/L*	**59 % Recovery** *50.0 - 130.0 % Recovery*	**<0.1**	**<0.1**	**B** *0.0 - 0.0 %*
TC0049DW Nodularin (intracellular)						
<0.1 ug/L	**F**		**E**	**<0.1**	**<0.1**	**B** *0.0 - 0.0 %*
TC0049DW Nodularin (total)						
<0.1 ug/L	**F**		**E**	**<0.1**	**<0.1**	**B** *0.0 - 0.0 %*
TC0061DW C1						
<0.5 ug/L	**<0.5**	**73** *70.0 - 130.0 ug/L*	**100 % Recovery** *50.0 - 130.0 % Recovery*	**<0.5**	**<0.5**	**B** *0.0 - 0.0 %*
TC0061DW C2						
<0.3 ug/L	**<0.3**	**110** *70.0 - 130.0 ug/L*	**130 % Recovery** *50.0 - 130.0 % Recovery*	**<0.3**	**<0.3**	**B** *0.0 - 0.0 %*

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

LOQ	Blank	Control *Acceptance Criteria*	Spike *Acceptance Criteria*	Duplicate1	Duplicate2	RPD *Acceptance Criteria*
TC0061DW dcGTX2						
<0.5 ug/L	**<0.5**	**76** *70.0 - 130.0 ug/L*	**120 % Recovery** *50.0 - 130.0 % Recovery*	**<0.5**	**<0.5**	**B** *0.0 - 0.0 %*
TC0061DW dcGTX3						
<0.3 ug/L	**<0.3**	**93** *70.0 - 130.0 ug/L*	**110 % Recovery** *50.0 - 130.0 % Recovery*	**<0.3**	**<0.3**	**B** *0.0 - 0.0 %*
TC0061DW dcNeo						
<0.5 ug/L	**<0.5**	**130** *70.0 - 130.0 ug/L*	**130 % Recovery** *50.0 - 130.0 % Recovery*	**<0.5**	**<0.5**	**B** *0.0 - 0.0 %*
TC0061DW dcSTX						
<0.5 ug/L	**<0.5**	**72** *70.0 - 130.0 ug/L*	**100 % Recovery** *50.0 - 130.0 % Recovery*	**<0.5**	**<0.5**	**B** *0.0 - 0.0 %*
TC0061DW GTX1						
<0.5 ug/L	**<0.5**	**82** *70.0 - 130.0 ug/L*	**130 % Recovery** *50.0 - 130.0 % Recovery*	**<0.5**	**<0.5**	**B** *0.0 - 0.0 %*
TC0061DW GTX2						
<1 ug/L	**<1**	**76** *70.0 - 130.0 ug/L*	**120 % Recovery** *50.0 - 130.0 % Recovery*	**<1**	**<1**	**B** *0.0 - 0.0 %*
TC0061DW GTX3						
<0.5 ug/L	**<0.5**	**120** *70.0 - 130.0 ug/L*	**120 % Recovery** *50.0 - 130.0 % Recovery*	**<0.5**	**<0.5**	**B** *0.0 - 0.0 %*

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

LOQ	Blank	Control *Acceptance Criteria*	Spike *Acceptance Criteria*	Duplicate1	Duplicate2	RPD *Acceptance Criteria*
TC0061DW GTX4						
<0.3 ug/L	**<0.3**	**110** *70.0 - 130.0 ug/L*	**120 % Recovery** *50.0 - 130.0 % Recovery*	**<0.3**	**<0.3**	**B** *0.0 - 0.0 %*
TC0061DW GTX5						
<0.5 ug/L	**<0.5**	**91** *70.0 - 130.0 ug/L*	**120 % Recovery** *50.0 - 130.0 % Recovery*	**<0.5**	**<0.5**	**B** *0.0 - 0.0 %*
TC0061DW GTX6						
<0.3 ug/L	**<0.3**	**110** *70.0 - 130.0 ug/L*	**130 % Recovery** *50.0 - 130.0 % Recovery*	**<0.3**	**<0.3**	**B** *0.0 - 0.0 %*
TC0061DW Neosaxitoxin						
<0.3 ug/L	**<0.3**	**100** *70.0 - 130.0 ug/L*	**130 % Recovery** *50.0 - 130.0 % Recovery*	**<0.3**	**<0.3**	**B** *0.0 - 0.0 %*
TC0061DW Saxitoxin						
<0.4 ug/L	**<0.4**	**82** *70.0 - 130.0 ug/L*	**110 % Recovery** *50.0 - 130.0 % Recovery*	**<0.4**	**<0.4**	**B** *0.0 - 0.0 %*

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

Extra Note:

F: Blank is not applicable for this analyte

E: Spike is not applicable for this analyte

DUPLICATE Anatoxin-a(extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Anatoxin-a(intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Anatoxin-a(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Cylindrospermopsin (extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Cylindrospermopsin (intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Cylindrospermopsin(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin LR(extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin LR(intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin LR(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin RR(extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

SPIKE Microcystin RR(extracellular) Spiking level less than 40 % of sample concentration

DUPLICATE Microcystin RR(intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin RR(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin YR(extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin YR(intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Microcystin YR(total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Nodularin (extracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Nodularin (intracellular) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Nodularin (total) B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE C1 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE C2 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE dcGTX2 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE dcGTX3 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE dcNeo B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE dcSTX B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX1 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX2 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX3 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX4 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX5 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE GTX6 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Neosaxitoxin B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

* Indicates NATA accreditation does not cover the performance of this service

Sydney WATER Laboratory Services

DUPLICATE Saxitoxin B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

* Indicates NATA accreditation does not cover the performance of this service